



ADDENDUM NO. 2

TO: All Plan holders and Prospective Bidders

FROM: City of Capitola Public Works

DATE: November 14, 2022

BID OPENING: 11:00AM Wednesday November 16, 2022

RE: **ADDENDUM NO. 2**
CITY HALL AND POLICE DEPARTMENT BACKUP GENERATOR

ADDENDUM NO. 2

City of Capitola, California

This Addendum shall be considered as a part of the bid documents for the subject project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original documents, this Addendum shall govern and take precedence.

Contractors are hereby notified that they shall make any necessary adjustments in their proposals on account of this Addendum. It will be construed that each proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Receipt of this Addendum must be acknowledged on the Addendum Acknowledgement form. Signature on said Bid Form indicates acknowledgement of receipt of Addendum No. 2, and that said Addendum No. 2 was properly evaluated in bidder's proposal. Any proposal not in compliance with this requirement may be rejected.

Jessica Kahn, Public Works Director

The following is hereby added and/or amended and is intended to add clarification to the following:

- 1. Base Bid Item No. 1 – Generator Purchase shall include**
 - a. The purchase and delivery of a Generator and Automatic Transfer Switch (Section 11.01 Automatic Transfer Switch)**
 - b. A Level 2 Sound Attenuated Steel Enclosure**
 - c. A 118 hour tank. This will be a base tank, not a remote tank**
 - d. No load bank is needed**

- 2. Contractor License –Contractor must hold a California Class A, General Engineering OR C-10, Electrical License.**

- 3. Liquidated Damages - \$2,900/day**
- 4. Bidders Bond – The need for a bidder’s bond (Section 2.08) has been waved and does not need to be included as part of the bid packet.**
- 5. Labor and Material Bond – No change, the need to provide a labor/material bond is still a requirement and must be provided within 10 calendar days after receiving written notice that the contract has been awarded.**